

17501
Ames Material lab-Replace VAV Box and Ductwork
Questions and Responses Set 1

Q1. Return Air?

R1. Return Air pulls wild.

Q2. Coils coming off?

R2. Yes, everything will be new.

Q3 Return Air in west side?

R3. Brett will provide blueprint on control lines also talk to Ashley and the Engineer on the Return Air for the west side for the awarded vendor.

Q4. Do you want insulation?

R4. Yes

Q2. Will there be painting involved?

R4. No

There are 9 VAV Boxes